

塞拉尼斯生产基地

2019年企业自测自报方案及报告

一、月度计划

序号	采样点名称	排口编号	排口坐标		监测因子		排放标准限值 (mg/l)	监测日期	污染物浓度 (mg/l)
			经度	纬度					
1	生产废水总排1	HGY-WS-01	118°47'55.169"	32°16'6.701"	1	COD	1000	4/10/2019	16
			118°47'55.169"	32°16'6.701"	2	pH	6.0~9.0	4/10/2019	7.63
			118°47'55.169"	32°16'6.701"	3	氨氮	50	4/10/2019	0.982
			118°47'55.169"	32°16'6.701"	4	总磷	5	4/10/2019	0.08
			118°47'55.169"	32°16'6.701"	5	悬浮物	400	4/10/2019	6
			118°47'55.169"	32°16'6.701"	6	总氮	70	4/10/2019	2.91
			118°47'55.169"	32°16'6.701"	7	石油类	20	4/10/2019	0.18
			118°47'55.169"	32°16'6.701"	8	硫化物	1	4/10/2019	0.041
			118°47'55.169"	32°16'6.701"	9	挥发酚	2	4/10/2019	ND
2	生产废水总排2	HGY-WS-03	118°47'47.836"	32°16'19.196"	1	COD	1000	4/10/2019	73
			118°47'47.836"	32°16'19.196"	2	pH	6.0~9.0	4/10/2019	7.51
			118°47'47.836"	32°16'19.196"	3	氨氮	50	4/10/2019	4.42
			118°47'47.836"	32°16'19.196"	4	总磷	5	4/10/2019	0.47
			118°47'47.836"	32°16'19.196"	5	悬浮物	400	4/10/2019	8
			118°47'47.836"	32°16'19.196"	6	总氮	70	4/10/2019	11.8
			118°47'47.836"	32°16'19.196"	7	石油类	20	4/10/2019	0.25
			118°47'47.836"	32°16'19.196"	8	硫化物	1	4/10/2019	0.046
			118°47'47.836"	32°16'19.196"	9	挥发酚	2	4/10/2019	ND
3	雨水（清下水）排口1	FWS-01	118°48'30.406"	32°16'25.910"	1	COD	40	4/10/2019	23
			118°48'30.406"	32°16'25.910"	2	pH	6.0~9.0	4/10/2019	7.21
			118°48'30.406"	32°16'25.910"	3	氨氮	2	4/10/2019	0.98
			118°48'30.406"	32°16'25.910"	4	总磷	0.4	4/10/2019	0.08
			118°48'30.406"	32°16'25.910"	5	悬浮物	50	4/10/2019	7
4	雨水（清下水）排口2	FWS-02	118°48'28.138"	32°16'27.347"	1	COD	40	4/10/2019	20
			118°48'28.138"	32°16'27.347"	2	pH	6.0~9.0	4/10/2019	8.36
			118°48'28.138"	32°16'27.347"	3	氨氮	2	4/10/2019	0.146

			118°48'28.138"	32°16'27.347"	4	总磷	0.4	4/10/2019	0.08
			118°48'28.138"	32°16'27.347"	5	悬浮物	50	4/10/2019	6
5	雨水（清下水）排口3	FWS-03	118°48'25.668"	32°16'29.950"	1	COD	40	4/10/2019	32
			118°48'25.668"	32°16'29.950"	2	pH	6.0~9.0	4/10/2019	6.42
			118°48'25.668"	32°16'29.950"	3	氨氮	2	4/10/2019	0.115
			118°48'25.668"	32°16'29.950"	4	总磷	0.4	4/10/2019	0.09
			118°48'25.668"	32°16'29.950"	5	悬浮物	50	4/10/2019	5
6	雨水（清下水）排口4	FWS-04	118°48'30.323"	32°16'36.505"	1	COD	40	4/10/2019	10
			118°48'30.323"	32°16'36.505"	2	pH	6.0~9.0	4/10/2019	7.52
			118°48'30.323"	32°16'36.505"	3	氨氮	2	4/10/2019	0.123
			118°48'30.323"	32°16'36.505"	4	总磷	0.4	4/10/2019	0.09
			118°48'30.323"	32°16'36.505"	5	悬浮物	50	4/10/2019	8
7	雨水（清下水）排口5	FWS-05	118°48'40.802"	32°16'39.626"	1	COD	40	4/10/2019	13
			118°48'40.802"	32°16'39.626"	2	pH	6.0~9.0	4/10/2019	7.81
			118°48'40.802"	32°16'39.626"	3	氨氮	2	4/10/2019	0.129
			118°48'40.802"	32°16'39.626"	4	总磷	0.4	4/10/2019	0.05
			118°48'40.802"	32°16'39.626"	5	悬浮物	50	4/10/2019	7
8	排气筒(Celstran)	FQ-11	118°47'55.180"	32°16'21.428"	1	非甲烷总烃	60	4/15/2019	1.36
9	排气筒（Celstran扩建）	FQ-13	118°48'37.292"	32°16'34.460"	1	非甲烷总烃	60	4/15/2019	1.33
10	挤出工段排气筒（七期 C0304）	FQ-15	118°47'58.366"	32°16'6.683"	1	非甲烷总烃	60	4/17/2019	0.25
11	挤出工段排气筒（七期 C0305）	FQ-21	118°47'58.366"	32°16'6.683"	1	非甲烷总烃	60	4/17/2019	0.27
12	马弗炉废气排气筒（七期）	FQ-17	118°47'55.126"	32°16'6.078"	1	非甲烷总烃	60	4/17/2019	0.2