

塞拉尼斯生产基地

2019年企业自测自报方案及报告

一、月度计划

序号	采样点名称	排口编号	排口坐标		监测因子		排放标准限值 (mg/l)	监测日期	污染物浓度 (mg/l)
			经度	纬度					
1	生产废水总排1	HGY-WS-01	118°47'55.169"	32°16'6.701"	1	COD	1000	6/12/2019	60
			118°47'55.169"	32°16'6.701"	2	pH	6.0~9.0	6/12/2019	8.18
			118°47'55.169"	32°16'6.701"	3	氨氮	50	6/12/2019	0.336
			118°47'55.169"	32°16'6.701"	4	总磷	5	6/12/2019	0.28
			118°47'55.169"	32°16'6.701"	5	悬浮物	400	6/12/2019	31
			118°47'55.169"	32°16'6.701"	6	总氮	70	6/12/2019	8.69
			118°47'55.169"	32°16'6.701"	7	石油类	20	6/12/2019	0.09
			118°47'55.169"	32°16'6.701"	8	硫化物	1	6/12/2019	0.021
			118°47'55.169"	32°16'6.701"	9	挥发酚	2	6/12/2019	ND
2	生产废水总排2	HGY-WS-03	118°47'47.836"	32°16'19.196"	1	COD	1000	6/12/2019	110
			118°47'47.836"	32°16'19.196"	2	pH	6.0~9.0	6/12/2019	8.17
			118°47'47.836"	32°16'19.196"	3	氨氮	50	6/12/2019	1.38
			118°47'47.836"	32°16'19.196"	4	总磷	5	6/12/2019	1.82
			118°47'47.836"	32°16'19.196"	5	悬浮物	400	6/12/2019	33
			118°47'47.836"	32°16'19.196"	6	总氮	70	6/12/2019	8.02
			118°47'47.836"	32°16'19.196"	7	石油类	20	6/12/2019	0.51
			118°47'47.836"	32°16'19.196"	8	硫化物	1	6/12/2019	0.079
			118°47'47.836"	32°16'19.196"	9	挥发酚	2	6/12/2019	ND
3	雨水（清下水）排口1	FWS-01	118°48'30.406"	32°16'25.910"	1	COD	40	6/12/2019	39
			118°48'30.406"	32°16'25.910"	2	pH	6.0~9.0	6/12/2019	8.65
			118°48'30.406"	32°16'25.910"	3	氨氮	2	6/12/2019	0.243
			118°48'30.406"	32°16'25.910"	4	总磷	0.4	6/12/2019	0.09
			118°48'30.406"	32°16'25.910"	5	悬浮物	50	6/12/2019	8
4	雨水（清下水）排口2	FWS-02	118°48'28.138"	32°16'27.347"	1	COD	40	6/12/2019	38
			118°48'28.138"	32°16'27.347"	2	pH	6.0~9.0	6/12/2019	8.51
			118°48'28.138"	32°16'27.347"	3	氨氮	2	6/12/2019	0.182

			118°48'28.138"	32°16'27.347"	4	总磷	0.4	6/12/2019	0.11
			118°48'28.138"	32°16'27.347"	5	悬浮物	50	6/12/2019	7
5	雨水（清下水）排口3	FWS-03	118°48'25.668"	32°16'29.950"	1	COD	40	6/12/2019	38
			118°48'25.668"	32°16'29.950"	2	pH	6.0~9.0	6/12/2019	8.52
			118°48'25.668"	32°16'29.950"	3	氨氮	2	6/12/2019	0.14
			118°48'25.668"	32°16'29.950"	4	总磷	0.4	6/12/2019	0.08
			118°48'25.668"	32°16'29.950"	5	悬浮物	50	6/12/2019	8
6	雨水（清下水）排口4	FWS-04	118°48'30.323"	32°16'36.505"	1	COD	40	6/12/2019	9
			118°48'30.323"	32°16'36.505"	2	pH	6.0~9.0	6/12/2019	8.57
			118°48'30.323"	32°16'36.505"	3	氨氮	2	6/12/2019	0.111
			118°48'30.323"	32°16'36.505"	4	总磷	0.4	6/12/2019	0.07
			118°48'30.323"	32°16'36.505"	5	悬浮物	50	6/12/2019	9
7	雨水（清下水）排口5	FWS-05	118°48'40.802"	32°16'39.626"	1	COD	40	6/12/2019	39
			118°48'40.802"	32°16'39.626"	2	pH	6.0~9.0	6/12/2019	8.55
			118°48'40.802"	32°16'39.626"	3	氨氮	2	6/12/2019	0.346
			118°48'40.802"	32°16'39.626"	4	总磷	0.4	6/12/2019	0.13
			118°48'40.802"	32°16'39.626"	5	悬浮物	50	6/12/2019	12
8	催化燃烧（VAM）R-201	FQ-06	118°47'58.610"	32°16'17.191"	1	非甲烷总烃	60	6/10/2019	0.365
9	排气筒(Celstran)	FQ-11	118°47'55.180"	32°16'21.428"	1	非甲烷总烃	60	6/10/2019	0
10	排气筒（Celstran扩建）	FQ-13	118°48'37.292"	32°16'34.460"	1	非甲烷总烃	60	6/10/2019	10.45
11	挤出工段排气筒（七期 C0304）	FQ-15	118°47'58.366"	32°16'6.683"	1	非甲烷总烃	60	6/5/2019	2.04
12	挤出工段排气筒（七期 C0305）	FQ-21	118°47'58.366"	32°16'6.683"	1	非甲烷总烃	60	6/5/2019	1.38
13	热洁炉废气排气筒（七期 V0601）	FQ-16	118°47'57.736"	32°16'7.115"	1	非甲烷总烃	60	未运行	/
14	热洁炉废气排气筒（七期 V0602）	FQ-22	118°47'57.736"	32°16'7.115"	1	非甲烷总烃	60	6/5/2019	0.95
15	马弗炉废气排气筒（七期）	FQ-17	118°47'55.126"	32°16'6.078"	1	非甲烷总烃	60	6/5/2019	0.47