

塞拉尼斯生产基地

2020年企业自测自报方案及报告

一、月度计划

序号	采样点名称	排口编号	排口坐标		监测因子		排放标准限值 (mg/l)	监测日期	污染物浓度 (mg/l)
			经度	纬度					
1	生产废水总排1	HGY-WS-01	118°47'55.169"	32°16'6.701"	1	COD	1000	1/15/2020	37
			118°47'55.169"	32°16'6.701"	2	pH	6.0~9.0	1/15/2020	8.16
			118°47'55.169"	32°16'6.701"	3	氨氮	50	1/15/2020	0.042
			118°47'55.169"	32°16'6.701"	4	总磷	5	1/15/2020	0.05
			118°47'55.169"	32°16'6.701"	5	悬浮物	400	1/15/2020	11
			118°47'55.169"	32°16'6.701"	6	总氮	70	1/15/2020	0.86
			118°47'55.169"	32°16'6.701"	7	石油类	20	1/15/2020	0.12
			118°47'55.169"	32°16'6.701"	8	硫化物	1	1/15/2020	0.0025
			118°47'55.169"	32°16'6.701"	9	挥发酚	2	1/15/2020	0.005
2	生产废水总排2	HGY-WS-03	118°47'47.836"	32°16'19.196"	1	COD	1000	1/15/2020	109
			118°47'47.836"	32°16'19.196"	2	pH	6.0~9.0	1/15/2020	7.87
			118°47'47.836"	32°16'19.196"	3	氨氮	50	1/15/2020	0.38
			118°47'47.836"	32°16'19.196"	4	总磷	5	1/15/2020	0.16
			118°47'47.836"	32°16'19.196"	5	悬浮物	400	1/15/2020	16
			118°47'47.836"	32°16'19.196"	6	总氮	70	1/15/2020	3.24
			118°47'47.836"	32°16'19.196"	7	石油类	20	1/15/2020	0.03
			118°47'47.836"	32°16'19.196"	8	硫化物	1	1/15/2020	0.0025
			118°47'47.836"	32°16'19.196"	9	挥发酚	2	1/15/2020	0.005
3	雨水 (清下水) 排口1	FWS-01	118°48'30.406"	32°16'25.910"	1	COD	40	1/15/2020	21
			118°48'30.406"	32°16'25.910"	2	pH	6.0~9.0	1/15/2020	7.96
			118°48'30.406"	32°16'25.910"	3	氨氮	2	1/15/2020	0.23
			118°48'30.406"	32°16'25.910"	4	总磷	0.4	1/15/2020	0.07
			118°48'30.406"	32°16'25.910"	5	悬浮物	50	1/15/2020	9
			118°48'30.406"	32°16'25.910"	5	石油类	\	1/15/2020	0.13
4	雨水 (清下水) 排口2	FWS-02	118°48'28.138"	32°16'27.347"	1	COD	40	1/15/2020	23
			118°48'28.138"	32°16'27.347"	2	pH	6.0~9.0	1/15/2020	7.88
			118°48'28.138"	32°16'27.347"	3	氨氮	2	1/15/2020	0.045

序号	采样点名称	排口编号	排口坐标		监测因子		排放标准限值 (mg/l)	监测日期	污染物浓度 (mg/l)
			经度	纬度					
4	雨水 (清下水) 排口2	FWS-02	118°48'28.138"	32°16'27.347"	4	总磷	0.4	1/15/2020	0.1
			118°48'28.138"	32°16'27.347"	4	悬浮物	50	1/15/2020	7
			118°48'28.138"	32°16'27.347"	5	石油类	\	1/15/2020	0.14
5	雨水 (清下水) 排口3	FWS-03	118°48'25.668"	32°16'29.950"	1	COD	40	1/15/2020	17
			118°48'25.668"	32°16'29.950"	2	pH	6.0~9.0	1/15/2020	18
			118°48'25.668"	32°16'29.950"	3	氨氮	2	1/15/2020	0.059
			118°48'25.668"	32°16'29.950"	4	总磷	0.4	1/15/2020	0.03
			118°48'25.668"	32°16'29.950"	4	悬浮物	50	1/15/2020	8
			118°48'25.668"	32°16'29.950"	5	石油类	\	1/15/2020	0.09
6	雨水 (清下水) 排口4	FWS-04	118°48'30.323"	32°16'36.505"	1	COD	40	1/15/2020	28
			118°48'30.323"	32°16'36.505"	2	pH	6.0~9.0	1/15/2020	7.93
			118°48'30.323"	32°16'36.505"	3	氨氮	2	1/15/2020	0.062
			118°48'30.323"	32°16'36.505"	3	总磷	0.4	1/15/2020	0.03
			118°48'30.323"	32°16'36.505"	4	悬浮物	50	1/15/2020	7
			118°48'30.323"	32°16'36.505"	5	石油类	\	1/15/2020	0.11
7	雨水 (清下水) 排口5	FWS-05	118°48'40.802"	32°16'39.626"	1	COD	40	1/15/2020	18
			118°48'40.802"	32°16'39.626"	2	pH	6.0~9.0	1/15/2020	7.99
			118°48'40.802"	32°16'39.626"	2	氨氮	2	1/15/2020	0.254
			118°48'40.802"	32°16'39.626"	3	总磷	0.4	1/15/2020	0.06
			118°48'40.802"	32°16'39.626"	4	悬浮物	50	1/15/2020	9
			118°48'40.802"	32°16'39.626"	5	石油类	\	1/15/2020	0.09
8	吸收塔 (AA) 新建罐区	FQ-01	118°48'1.937"	32°16'13.368"	1	非甲烷总烃	80	1/17/2020	0.08
9	吸收塔 (AA) 初始罐区	FQ-08	118°47'55.561"	32°16'11.618"	1	非甲烷总烃	80	1/17/2020	0.14
10	废水处理系统排放口 (V AE)	FQ-32	118°48'34.643"	32°16'32.930"	1	非甲烷总烃	80	1/17/2020	0.42
			118°48'34.643"	32°16'32.930"	2	硫化氢	5	1/17/2020	0.04
11	催化燃烧 (VAM) R-201	FQ-06	118°47'58.610"	32°16'17.191"	1	非甲烷总烃	60	1/17/2020	0.64
12	水洗塔 (VAM)	FQ-07	118°47'58.024"	32°16'14.282"	1	非甲烷总烃	80	1/17/2020	0.08
13	排气筒(Celstran)	FQ-11	118°47'55.180"	32°16'21.428"	1	非甲烷总烃	60	1/17/2020	0.1

序号	采样点名称	排口编号	排口坐标		监测因子		排放标准限值 (mg/l)	监测日期	污染物浓度 (mg/l)
			经度	纬度					
14	排气筒 (Celstran扩建)	FQ-13	118°48'37.292"	32°16'34.460"	1	非甲烷总烃	60	1/17/2020	0.32
15	挤出工段排气筒 (七期 C0304)	FQ-15	118°47'58.366"	32°16'6.683"	1	非甲烷总烃	60	1/17/2020	0.12
16	挤出工段排气筒 (七期 C0305)	FQ-21	118°47'58.366"	32°16'6.683"	1	非甲烷总烃	60	1/17/2020	0.1
17	热洁炉废气排气筒 (七期 V0601)	FQ-16	118°47'57.736"	32°16'7.115"	1	非甲烷总烃	60	未运行	/
18	热洁炉废气排气筒 (七期 V0602)	FQ-22	118°47'57.736"	32°16'7.115"	1	非甲烷总烃	60	1/17/2020	0.09
19	马弗炉废气排气筒 (七期)	FQ-17	118°47'55.126"	32°16'6.078"	1	非甲烷总烃	60	1/17/2020	0.18